



Date	Time	Phone	Last Service Date
			Extinguishers
Business Name		Fax	Alarms
			Sprinklers
Owner/Manager Name		Occupancy	Hood
			Knox Box
Address			Correction Date
			Re-inspected

Your attention is called to the following violations of the International Fire Code and/or other applicable Local, State and National Codes.

Fire Prevention Inspection Report

- | | |
|--|--|
| <ul style="list-style-type: none"> <input type="checkbox"/> No Deficiencies Found <input type="checkbox"/> Please correct the following violation(s) on or before the date listed. <input type="checkbox"/> 901 Have your fire alarm system, fire sprinkler systems and portable extinguishers serviced by a certified technician. This must be accomplished on at least an annual basis. <input type="checkbox"/> 609.1 Have your range hood suppression system serviced every six months by a certified technician to comply with IMC. <input type="checkbox"/> 304.3.3 Dumpsters shall not be within 5 feet of combustible wall or eve. <input type="checkbox"/> 315.2 Storage of combustible materials in buildings shall be orderly. <input type="checkbox"/> 315.2.1 Ceiling clearance. Storage shall be maintained 2 feet or more below the ceiling in non sprinklered areas of buildings or a minimum of 18 inches below sprinkler head deflectors in sprinklered areas of buildings. <input type="checkbox"/> 315.2.2/3 Combustible materials shall not be stored in exits or exit enclosures. Combustible materials shall not be stored in boiler rooms, mechanical rooms or electrical equipment rooms. <input type="checkbox"/> 404.4 Provide approved evacuation plan. <input type="checkbox"/> 505.1.1 Address numbers for commercial buildings shall be:
 0' - 50' from street or less: 6 - 12" minimum height;
 50' to 100' from street: 12 - 18" minimum height;
 more than 100' from street: 18 - 24" minimum height. <input type="checkbox"/> 506.1 Provide a Knox Box to be installed in an approved location. Provide keys necessary for access. <input type="checkbox"/> 605.3 A working space of not less than 30 inches in width, 36 inches in depth and 78 inches in height shall be provided in front of electrical service equipment. <input type="checkbox"/> 605.1 Identified electrical hazards shall be abated. Identify all breakers. Provide cover plates for all electrical boxes and remove all multi-plug adapters. <input type="checkbox"/> 605.3.1 Doors into electrical control panel rooms or fire protection systems shall be marked with a plainly visible and legible sign. <input type="checkbox"/> 605.5 Extension cords and flexible cords shall not be a substitute for permanent wiring. Extension cords shall be used only with portable appliances. <input type="checkbox"/> 605.6 Open junction boxes and open wiring splices shall be prohibited. Approved covers shall be provided. | <ul style="list-style-type: none"> <input type="checkbox"/> A re-inspection will be made at the end of a specified time. <input type="checkbox"/> When you change door locks, call 360-275-6711. <input type="checkbox"/> 703.1 Maintain fire rated construction. <input type="checkbox"/> 703.2.2 Remove door hold open devices/doors equipped with automatic door closers shall be maintained in the closed position. <input type="checkbox"/> 901.6.1/2 Provide service and test records for fire protection systems. <input type="checkbox"/> 903.3.7 Fire Department connections shall be provided with threaded caps or covers/FDCs shall be immediately accessible. <input type="checkbox"/> 1003.6 Obstructions shall not be placed in the required width of a means of egress. Exits shall not be obstructed in any manner. <input type="checkbox"/> 1006.1 The means of egress, including the exit discharge, shall be illuminated at all times. <input type="checkbox"/> 1008.1.8 and 1008.1.8.3 Exit doors shall be openable from the inside without a key or special knowledge or effort. Double keyed deadbolts are not allowed. Post a sign "<i>This door to remain unlocked during business hours.</i>" <input type="checkbox"/> 1011.1 Exit signs shall be internally or externally illuminated. Exits and exit doors shall be marked by an approved exit sign readily visible from any direction of egress travel. <input type="checkbox"/> 3003.2 Stationary and portable compressed gas containers, cylinders, tanks and systems shall be marked and secured against unauthorized entry and safeguarded in an approved manner. 3003.2.1, 3003.2.2, 3003.2.3 and 3003.3.1. <input type="checkbox"/> 2205.3.1 Provide at least 50 pounds of rice hulls or other approved absorbent and at least 25 approved absorbent pads, minimum dimension 16 inch by 16 inch and/or other spill control equipment. <input type="checkbox"/> 3403.3.2 Provide a flammable liquids storage cabinet. <input type="checkbox"/> 3403.5.3 Warning labels. Individual containers, packages and cartons shall be identified, marked, labelled and placarded in accordance with federal regulations and applicable state laws. Provide MSDS sheets. <input type="checkbox"/> 3404.2.13.1.2/3 Underground storage tanks need to be capped within 90 days and removed within 1 year. |
|--|--|

Owner/Manager:	Inspector:
----------------	------------